

Errata to IEEE GUIDE TO THE MEASUREMENT OF PARTIAL DISCHARGES IN ROTATING MACHINERY

Sponsor

Electric Machinery Committee
of the
IEEE Power Engineering Society

Correction Sheet
Issued 19 August 2005

Copyright © 2005 by the Institute of Electrical and Electronics Engineers, Inc. All rights reserved. Published 2005.
Printed in the United States of America.

This correction sheet may be freely reproduced and distributed in order to maintain the utility and currency of the underlying Standard. This correction sheet may not be sold, licensed or otherwise distributed for any commercial purposes whatsoever. The content of this correction sheet may not be modified.

Page 2, Clause 2 References

IEC 60270(1981-01), Partial Discharge Measurements.

should be changed to read as follows:

IEC 60270(1996-01), Partial Discharge Measurements.

(*This should also be changed in Clause 8 and 10.2.3.*)

IEEE Std 286-2000, IEEE Recommended Practice for Measurement of Power Tip-Up of Rotating Machinery Stator Coil Insulation.

should read as follows:

IEEE Std 286-2000, IEEE Recommended Practice for Measurement of Power Tip-Up of Electric Machinery Stator Coil Insulation.

Page 3, Clause 3 Definitions, 3.1 apparent charge should read as follows:

3.1 apparent charge: The apparent charge (Q) of an individual partial discharge (PD) is that charge which, if injected instantaneously between the terminals of the test object, would momentarily change the voltage between its terminals by the same amount as the partial discharge itself. The apparent charge is expressed in coulombs.

Page 5, Clause 3 Definitions, 3.24 partial discharge (PD) quantity should read as follows:

3.24 partial discharge (PD) quantity: The magnitude of an individual discharge in an insulation system expressed in terms of the apparent charge transfer (Q) measured at the terminals of the test object expressed in coulombs. In the case of complete windings, such measurements are limited to the frequency range of 10 kHz to 1 MHz, and the results obtained are a function of the bandwidth of the particular detection system.

Page 8, Clause 3 Definitions, 3.28 pulse discharge should read as follows:

3.28 pulse discharge: A type of partial discharge (PD) phenomenon characterized by a spark-type breakdown. The resultant detected pulse discharge has a short rise time, and its frequency spectrum may extend as far as ≥ 100 MHz. Such a pulse discharge may be readily detected at the terminals of the winding or component under tests by means of conventional pulse detectors, that are generally designed for PD measurements within the frequency band from 10 kHz to several megahertz.

Page 31, first paragraph, there are two references to footnote 12, these should be changed to footnote 13.

Page 41, 11.4 Integrated quantities

The first item in the dashed list, *NQN*: The reference to 3.24 should be changed to 3.17.

The second item in the dashed list, *Quadratic rate*: The reference to 3.23 should be changed to 3.32.

Page 42, 11.5, last sentence in 4th item in dashed list should read as follows:

Surface discharges, especially, will be more prominent at low gas pressure.