

IEEE Std C37.04™-2018
(Revision of
IEEE Std C37.04-1999)

Errata to IEEE Standard for Ratings and Requirements for AC High-Voltage Circuit Breakers with Rated Maximum Voltage Above 1000 V

Developed by the
Switchgear Committee
of the
IEEE Power and Energy Society

Correction Sheet
Issued 14 August 2019

Copyright 2019 by the Institute of Electrical and Electronics Engineers, Inc.
All rights reserved. Published 14 August 2019. Printed in the United States of America.

This correction sheet may be freely reproduced and distributed in order to maintain the utility and currency of the underlying Standard. This correction sheet may not be sold, licensed or otherwise distributed for any commercial purposes whatsoever. The content of this correction sheet may not be modified.

In subclause 5.7.1, change the first sentence to include cross-reference as follows:

5.7 Transient recovery voltage (TRV)

5.7.1 General

The TRV related to the rated short-circuit interrupting current in accordance with 5.6 is the reference voltage that constitutes the limit of the prospective TRV of circuits, which the circuit breaker shall be capable of withstanding under fault conditions.