

# IEEE P2800

Draft Standard for Interconnection and Interoperability of  
Inverter-Based Resources Interconnecting with  
Associated Transmission Electric  
Power Systems

Virtual Working Group Meeting  
ConfCall 1 of 3 – *Post-Meeting Slide Deck* **with Minutes**

Jens C. Boemer, WG Chair\*


Kevin Collins, Bob Cummings, Babak Enayati, Ross Guttromson,  
Manish Patel, Chenhui Niu, Vice-Chairs  
Wes Baker, Secretary – Diwakar Tewari, Treasurer

November 21, 2019

\*Also Chair of the sponsoring  
ED&PG Wind and Solar Plant  
Interconnection Working Group  
([Link to Website](#))

# How To Log WG Meeting Attendance via IEEE iMAT?

- Anyone with an IEEE account can sign up at <https://development.standards.ieee.org/my-site/home> to receive P2800 Working Group updates (“Participant”).
- Participants can attend WG meetings and log their attendance via <https://imat.ieee.org/>. Must attend two consecutive meetings to become a “Voting Member”, i.e., get access to [iMeet](#) and to vote.
- Only IEEE SA members can ballot P2800.



\* Log WG Mtg attendance via iMAT ([imat.ieee.org](https://imat.ieee.org))

\*\* Available at <https://iee-sa.imeetcentral.com/p2800-0-wspi-p>

1. On the [myProject™ Home Screen](#), select “**Manage Activity Profile**”.
2. On the “Manage Activity Profile” Page, enter “**WSPI**” into the **Search** line and click “Search”.
3. **Check the boxes next to the activity you are interested in** (Sponsor, Working Group, Project). Check both the respective working group(s) and project(s).
4. Click “**CONTINUE**”
5. Confirm your interest area and enter your affiliation information.
6. Select from the list or type in your company/organization.
7. Click “**CONTINUE**”

The screenshot shows the 'myProject™ >> All Technical Areas' page. A search bar contains 'WSPI' and a 'SEARCH' button. Below the search bar, there are two main sections: 'Working Groups' and 'Projects'. Each section has a 'Join/Remove Interest Area' column with checkboxes, a 'Designator' column, and a 'Project Name' column. Red and purple callout boxes with arrows point to the checkboxes for 'Check for P2800' and 'Check for P2800.1' in both sections. At the bottom, there are 'CONTINUE' and 'CANCEL' buttons.

# IEEE iMAT

[Attendance](#) | [Reports](#) | [Events](#) | [Setup](#) | [Export](#)



Home - Jens Boemer, SA PIN: 74273

Welcome to the IEEE Attendance Tracking system. This system provides on-site home tracking integrated with the IEEE myProject™ system. You can view your prior attendance on the [Attendance History Report](#).

## Active Meetings

There are no meetings active for attendance at this time.

## Upcoming Meetings

IEEE P2800 Working Group Virtual Meeting - Call 1/3 21-Nov-2019

Attendance



Home >> Attendance >> WSPPID/WSPI/WSPI-P

## PE/EDPG/WSPPID/WSPI/WSPI-P Attendance Log

Attendee: William Baker, SA-Pin: 89311

Affiliations: PE/EDPG/WSPPID/WSPI/WSPI-P Power Grid Engineering

WED

20-Nov-2019

2

Schedule

7:00 8:00 9:00 10:00 11:00 12:00 13:00 14:00 15:00 16:00 17:00 18:00 19:00 20:00 21:00 22:00 23:00

breakout

Please record your attendance for an active breakout (denoted by yellow bar) by clicking on the yellow bar. Once your attendance has been recorded, the yellow bar changes to a green bar.

Submittal: As the person submitting this form, I certify that:

1. I am submitting this attendance record for myself and not someone else. DO NOT SUBMIT FOR OTHERS!
2. At the time of the submittal, I am currently in the Event above.

Confidentiality: All user contact information is considered confidential and is to be released (from this system) only to IEEE authorized personnel (Staff and Chairs)


# Establishment of Quorum

- WG Voting Members have access to iMeet and are kindly asked to record their attendance at [https://ieee-sa.imeetcentral.com/p/aQAAAAAD\\_hQ6](https://ieee-sa.imeetcentral.com/p/aQAAAAAD_hQ6)

← → ↻ 🏠 [ieee-sa.imeetcentral.com/p2800-wspi-p/folder/WzlwLDEyNDIwMTk2XQ/WzlsNjY5ODI5NzBd/?m=1&pgref=](https://ieee-sa.imeetcentral.com/p2800-wspi-p/folder/WzlwLDEyNDIwMTk2XQ/WzlsNjY5ODI5NzBd/?m=1&pgref=)

**IEEE SA** STANDARDS ASSOCIATION 🔍 Search for Workspaces and Files Create ▾

🗨 **IEEE P2800 Working Group Virtual Meeting - Call 1/3 (Nov 21, 2019) - Establishment of Quorum**  
📁 ED&PG P2800 Wind and Solar Plant Interconnection Performance Working Group (WSPI-P) / 📁 Draft Documents / 📁 Meeting Notices / 📁 2019-11-21\_WG Meeting (Virtual)

 **Jens C. Bogmer**  
Dear P2800 Working Group Voting Members,

Please use the vote below to track your attendance at the IEEE P2800 Working Group Virtual Meeting - Call 1/3 on Nov 21, 2019. We may compare this with the Webex reports to validate your attendance.

We will need 60 Voting Members to reach a Quorum.

Thanks,  
Jens

**I am attending the IEEE P2800 Working Group Virtual Meeting - Call 1/3 (Nov 21, 2019)**

Remotely via Webex

Vote ☐

Not at all

Vote ☐

Total Votes: 0

0min ago 👍 Like

Comments Sort oldest first ▾

**DETAILS**  
1 Draft · Modi  
**Tags**  
Add tags

# Meeting Goals

1. Convene Working Group and report on Sub-WGs' progress to date.
2. Inform WG and all Sub-WG members about latest list of definitions (Clause 3.1) developed by SubGroups I & II.
3. Identify 1 to 3 key issues per SubGroup that need discussion and possibly voting for WG direction.

# **IEEE SA Rules, Standards Classification & Language**

# Guidelines for IEEE WG meetings

- All IEEE-SA standards meetings shall be conducted **in compliance with all applicable laws**, including **antitrust** and **competition** laws.
  - Don't discuss the interpretation, validity, or essentiality of **patents/patent claims**.
  - Don't discuss specific **license rates, terms, or conditions**.
    - Relative costs of different technical approaches that include relative costs of patent licensing terms may be discussed in standards development meetings.
      - Technical considerations remain the primary focus
  - Don't discuss or engage in the fixing of **product prices, allocation of customers, or division of sales markets**.
  - Don't discuss the status or **substance of ongoing or threatened litigation**.
  - **Don't be silent** if inappropriate topics are discussed ... do formally object.
- For more details, see **IEEE-SA Standards Board Operations Manual**, clause 5.3.10 and Antitrust and Competition Policy: What You Need to Know at <http://standards.ieee.org/develop/policies/antitrust.pdf>



# Participants have a duty to inform the IEEE

- Participants shall **inform the IEEE** (or cause the IEEE to be informed) of the **identity of *each* holder** of any **potential Essential Patent Claims**
  - that are **potentially essential to implementation of the proposed standard(s)**
  - of which they are personally aware if the claims are owned or controlled by the participant or the entity the participant is from, employed by, or otherwise represents
- Participants should inform the IEEE (or cause the IEEE to be informed) of the identity of ***any other* holders** of potential Essential Patent Claims
- **Early identification** of holders of potential Essential Patent Claims is **encouraged**
- *The WG Chair informed the WG that Officers were made aware of 3 potential Essential Patent Claims to date and encouraged WG members to submit others by e-mail. No further claims were made during the call.*



# Ways to inform IEEE

- Cause an **LOA to be submitted** to the IEEE-SA (patcom@ieee.org); or
- Provide the **chair of this group** with the identity of the holder(s) of any and all such claims as soon as possible; or
- **Speak up now** and respond to this Call for Potentially Essential Patents
- If anyone in this meeting is personally aware of the holder of **any patent** claims that are **potentially essential to implementation of the proposed standard(s)** under consideration by this group and that are not already the subject of an Accepted Letter of Assurance, **please respond at this time** by providing relevant information to the WG Chair

# Patent-related information

The patent policy and the procedures used to execute that policy are documented in the:

- *IEEE-SA Standards Board Bylaws*  
(<http://standards.ieee.org/develop/policies/bylaws/sect6-7.html#6>)
- *IEEE-SA Standards Board Operations Manual*  
(<http://standards.ieee.org/develop/policies/opman/sect6.html#6.3>)

Material about the patent policy is available at

<http://standards.ieee.org/about/sasb/patcom/materials.html>

If you have questions, contact the IEEE-SA  
Standards Board Patent Committee Administrator  
at [patcom@ieee.org](mailto:patcom@ieee.org)

## IEEE SA COPYRIGHT POLICY

---

NOVEMBER 2019

# INSTRUCTIONS FOR CHAIRS OF STANDARDS DEVELOPMENT ACTIVITIES

---

At the beginning of each standards development meeting the chair or a designee is to:

- Show the following slides (or provide them beforehand)
- Advise the standards development group participants that:
- IEEE SA's copyright policy is described in Clause 7 of the IEEE SA Standards Board Bylaws and Clause 6.1 of the IEEE SA Standards Board Operations Manual;
- Any material submitted during standards development, whether verbal, recorded, or in written form, is a Contribution and shall comply with the IEEE SA Copyright Policy;
- Instruct the Secretary to record in the minutes of the relevant meeting:
- That the foregoing information was provided and that the copyright slides were shown (or provided beforehand).

## IEEE SA COPYRIGHT POLICY

---

By participating in this activity, you agree to comply with the IEEE Code of Ethics, all applicable laws, and all IEEE policies and procedures including, but not limited to, the IEEE SA Copyright Policy.

- Previously Published material (copyright assertion indicated) shall not be presented/submitted to the Working Group nor incorporated into a Working Group draft unless permission is granted.
- Prior to presentation or submission, you shall notify the Working Group Chair of previously Published material and should assist the Chair in obtaining copyright permission acceptable to IEEE SA.
- For material that is not previously Published, IEEE is automatically granted a license to use any material that is presented or submitted.

# IEEE SA COPYRIGHT POLICY



---

- The IEEE SA Copyright Policy is described in the IEEE SA Standards Board Bylaws and IEEE SA Standards Board Operations Manual
  - IEEE SA Copyright Policy, see  
Clause 7 of the IEEE SA Standards Board Bylaws  
<https://standards.ieee.org/about/policies/bylaws/sect6-7.html#7>  
Clause 6.1 of the IEEE SA Standards Board Operations Manual  
<https://standards.ieee.org/about/policies/opman/sect6.html>
- IEEE SA Copyright Permission
  - <https://standards.ieee.org/content/dam/ieee-standards/standards/web/documents/other/permissionltrs.zip>
- IEEE SA Copyright FAQs
  - <http://standards.ieee.org/faqs/copyrights.html/>
- IEEE SA Best Practices for IEEE Standards Development
  - [http://standards.ieee.org/develop/policies/best\\_practices\\_for\\_ieee\\_standards\\_development\\_051215.pdf](http://standards.ieee.org/develop/policies/best_practices_for_ieee_standards_development_051215.pdf)
- Distribution of Draft Standards (see 6.1.3 of the SASB Operations Manual)
  - <https://standards.ieee.org/about/policies/opman/sect6.html>


# IEEE Standards Classification & Language






**Standards**  
documents  
specifying mandatory  
requirements (***shall***)



**Recommended Practices**  
documents in which procedures  
and positions preferred by the  
IEEE are presented (***should***)




**Guides**  
documents that furnish information – e.g.,  
provide alternative approaches for good  
practice, suggestions stated but no clear-cut  
recommendations are made (***may***)





# Establishment of Quorum

- WG Voting Members have access to iMeet and are kindly asked to record their attendance at [https://ieee-sa.imeetcentral.com/p/aQAAAAAD\\_hQ6](https://ieee-sa.imeetcentral.com/p/aQAAAAAD_hQ6)



IEEE SA STANDARDS ASSOCIATION

Search for Workspaces and Files

### IEEE P2800 Working Group Virtual Meeting - Call 1/3 (Nov 21, 2019) - Establishment of Quorum

ED&PG P2800 Wind and Solar Plant Interconnection Performance Working Group (WSP1-P) / Meeting Notices / 2019-11-21\_WG Meeting (Virtual)

**You are in READ ONLY mode. Any changes you make will not be saved.**

**Jens C. Boemer**  
Dear P2800 Working Group Voting Members,

Please use the vote below to track your attendance at the IEEE P2800 Working Group Virtual Meeting - Call 1/3 on Nov 21, 2019. We may compare this with the Webex reports to validate your attendance.

We will need 60 Voting Members to reach a Quorum.

Thanks,  
Jens

I am attending the IEEE P2800 Working Group Virtual Meeting - Call 1/3 (Nov 21, 2019)

My Vote	Remotely via Webex ( 98.04% 50 votes )
ReVote	Not at all ( 1.96% 1 vote )
Total Votes: 51	

19hrs ago Like

Comments Sort oldest first

- *There was no quorum at the time.*

# Previous Meetings' Minutes

- Brief review of the minutes from the WG Meeting in September 2019 available on iMeetCentral [here](#).
- Motion to approve the minutes.
  - *There was no quorum at the time and minutes remain unapproved.*
  - *A new motion to approve the minutes will be made at the next WG meeting.*


# Review and Approval of Agenda

Refer to Word document on iMeetCentral [here](#).

- *There were no requests for changes of the agenda and the meeting continued respectively.*
- *There was no quorum at the time and the agenda remains unapproved.*

# Review of P2800 Scope & Updated Timeline

# Existing North American Standards for Inverter-Based Generating Resources and Gaps



<sup>1</sup> NERC definition of Bulk Electric System: ≥100 kV with gross individual / aggregate nameplate rating greater than 20 MVA / 75 MVA

<sup>2</sup> DER connected at typical (radial) primary and secondary voltage levels


<sup>3</sup> transmission and meshed sub-transmission

IEEE standards are voluntary industry standards and must be adopted by the appropriate authority to become mandatory.

# What to expect from IEEE P2800?

- Specify performance and functional *capabilities*.
- Specify functional *default settings*.
- Specify functional *ranges of allowable settings*.
- Specify modeling data, and measurement data for performance monitoring and validation.
- Specify required tests and verifications, but not their detailed procedures (→ P2800.1)

# Updated Timeline With Stretch Goals



\* Please contact the SubGroup leads and sign up for their Mailing Lists to engage.

\*\* The P2800 PAR states June 2021 for Initial Sponsor Ballot and October 2022 for submission to RevCom.

\*\*\* The P2800.1 PAR states Dec 2021 for Initial Sponsor Ballot and October 2022 for submission to RevCom.

**The ability to meet this tentative timeline may be subject to strong commitments of Working Group leadership team, i.e., support/funding.**



# Next Deliverables & Milestones

Deliverable	Due date for SubGroup submissions		Publication date
Draft 1.1 (Annotated)	Oct 31, 2019 (Officer Comments)	Nov 6, 2019 (Posted on iMeet)	
WG ConfCall	Nov 21, 2019 – discuss & vote on important decisions, e.g., Definitions		
WG ConfCall	Dec 6, 2019 – discuss & vote on 1-2 important decisions per SubGroup		
WG ConfCall	Dec 17, 2019 – discuss & vote on 1-2 important decisions per SubGroup		
<u>Informal</u> WG Meeting & <u>Voluntary</u> SubGroup Meetings	Jan 13, <del>2019</del> 2020, 1p-5p ET @2020 IEEE JTCM, Jacksonville, FL (does not count towards WG membership)		
WG ConfCall	Feb 6, <del>2019</del> 2020* – discuss & vote on 1-2 important decisions per SubGroup		
<b>Milestone:</b> Draft 2 (Complete Draft)	Mar 1, 2020* (SubGroup Input)	Mar 15, 2020* (Posted on iMeet)	
WG Meeting	TBD (April 7-9), 2020* (2 ½ days), FirstSolar, Tempe, AZ		
Draft 2.1	April 15, 2020* (SubGroup Posted)	May 1, 2020 (Comments in spreadsheet)	
<b>Milestone:</b> Draft 3	June 15, 2020* (Input)	June 30, 2020* (Posted on iMeet)	
WG Meeting	TBD (July 14-16), 2020*, Location TBD		
<b>Milestone:</b> WG Vote on Draft 3.x	TBD (July 23), 2020*		
Sponsor Coms Approve WG Draft	August 3-7, 2020 at PES General Meeting, Montreal, Canada		
Initial Ballot	Q3/2020*		
Recirculation	Q4/2020*		
<b>Milestone:</b> Submission to NesCom	Q1/2021*		
<b>Milestone:</b> Publication	Q2/2021*		

\* Tentative dates

# 2019/2020 Meetings

- Coordinated with NERC IRPTF Meeting Schedule and IEEE Meetings, as appropriate
- Webex for remote participation is available & counts towards WG meeting attendance
- Striving for no registration fee, as facilities and catering may be provided in-kind

IEEE P2800	Location	Registration
May 22-23, 2019	Atlanta, GA (NERC)	<a href="#">via vtools</a>
September 25-26, 2019	Salt Lake City, UT (WECC)	<a href="#">via 123signup</a>
<del>December 4-5, 2019</del>	<del>Tempe, AZ (FirstSolar)</del>	Cancelled
November 21, 2019	Webex (2:00p–4:00p ET)	<a href="#">Webex</a>
December 6, 2019	Webex (noon–2:00p ET)	<a href="#">Webex</a>
December 17, 2019	Webex (noon–2:00p ET)	<a href="#">Webex</a>
January 13, 2020, 1p-5p*	Jacksonville, FL (IEEE JTCM)	<a href="#">available here</a>
TBD (April 7-9), 2020	Tempe, AZ (FirstSolar)	N/A yet
TBD (July 14-16), 2020	TBD	N/A yet

NERC IRPTF
Tue/Wed, May 21-22, 2019
Wed/Thu, September 4-5, 2019
Tue/Wed, December 3-4, 2019

\* This is an informal WG Meeting with voluntary Sub-WG meetings (does not count towards WG membership)

# Informal WG Meeting at IEEE JTCM in Jacksonville, FL on Jan 13, 2020, 1p-5p

Webex Questions: *Do you plan to attend the Jan 13, 2020, informal meeting at the JTCM?*


- A. Yes, in person 22/76 (29%)
- B. Yes, remotely 40/76 (53%)
- C. No 13/76 (17%)
  
- No Answer 1/76 (1%)
- *For the draft agenda, refer to the right.*

## DRAFT AGENDA - Monday, 1/13/2020: 1PM – 5PM

1:00 PM	Welcome  Facility safety and emergency procedures  Opening remarks, objectives of this meeting	J. Boemer (remotely)
1:10 PM	Status Update on IEEE P2800	J. Boemer (remotely)
1:20 PM	Status Update on IEEE P2800.1	C. Niu / J. Boemer (remotely)
1:30 PM	Questions & Answers	All (on-site & remotely)
2:00 PM	Joint SubGroup Break-Out (M. Patel, B. Cummings, B. Enayati) <ul style="list-style-type: none"> <li>VII. Ride-Through Capability Requirements</li> <li>VIII. Ride-Through Performance Requirements</li> <li>IX. IBR Protection</li> </ul>	SubGroup VI. Power Quality Break-Out (R. Guttromson) - tentative <ul style="list-style-type: none"> <li>VII. Ride-Through Capability Requirements</li> <li>VIII. Ride-Through Performance Requirements</li> </ul>
3:15 PM	Break	
3:45 PM	(cont.)	(cont.)
5:00 PM	Adjourn	

# Presentation of definitions developed in SG1 + 2

- Refer to Word file on iMeet [here](#).
- *The updated has been posted to iMeet [here](#).*



# Test & verification requirements in P2800 vs. P2800.1

	P2800	P2800.1
1) Any <b>performance requirement</b> that can be verified <i>with any of the verification methods below*</i>	X	
2) For each performance requirements from 1), specify <b>which verification method</b> * shall be used <ul style="list-style-type: none"> <li><i>Current practice for BPS-resources is verification of performance by post-event analysis</i></li> <li><i>SubGroup XI. (Tests and verification requirements) to start with a structure similar to Tables 43 and 44 in IEEE 1547-2018 but need to add additional column(as) as needed. See next slide for details.</i></li> </ul>	X	
3) For each performance requirement from 1), specify guidelines for detailed <b>verification procedures</b> (step-by-step instructions) regarding <b>how</b> to conduct the required verification method * <ul style="list-style-type: none"> <li><i>SubGroup XI. (Tests and verification requirements) to start with P1547.1 Draft 9.6 (Recirc 2)</i></li> </ul>		X

## \* Potential Verification methods

- Type Tests (NRTL, manufacturer)
- Production Tests (manufacturer)
- IBR Evaluations (IBR developer and/or TEPS operator)
  - Need to decide whether modeling will be a "shall" or a "may" requirement in P2800.*
  - Could specific be included as a recommended practice in an P2800 appendix?*
  - Guidance on how to use modeling for verification purposes could be given in P2800.1.*
- Commissioning Tests
  - May include post-interconnection measurements if a "Conditional Permission to Operate" has been issued*
- Periodic Tests (Lifecycle, Major Changes)
- Post-Event Analysis (use of digital fault recordings, need to define what to measure)*

# Examples from Clause 11 of IEEE 1547-2018

**Modeling?**

Requirement	Compliance at PCC achieved by:	Type tests	<b>IBR</b> evaluation	Commissioning tests
<b>6.4 Voltage</b>				
6.4.1 Mandatory voltage tripping requirements	DER System	R	Design: R <sup>a</sup> Installation: R <sup>b</sup>	D
	Composite	L	Design: R <sup>a</sup> Installation: R <sup>b</sup>	D
6.4.2.1 General requirements and exceptions	DER System	R	R	D
	Composite	L	R	D <sup>a</sup>
6.4.2.2 Voltage disturbances within continuous operation region	DER System	R	Design: R <sup>a</sup> Installation: R <sup>b</sup>	D
	Composite	L	R	D <sup>a</sup>

■ Review Tables 43 and 44 of IEEE Std 1547™-2018 as needed: **R** Required; **L** Limited; **D** Depends

# Criteria for drafting these tables

- Size
  - Small: optional?
  - Large: mandatory?
- Requirement



***Thank you for your participation!***

# Contacts

## IEEE P2800

- Jens C Boemer,  
[j.c.boemer@ieee.org](mailto:j.c.boemer@ieee.org)
- Wes Baker,  
[wbaker@powergridmail.com](mailto:wbaker@powergridmail.com)


## IEEE P2800.1

- Chenhui Niu,  
[niuchenhui@sgepri.sgcc.com.cn](mailto:niuchenhui@sgepri.sgcc.com.cn)
- Jens C Boemer,  
[j.c.boemer@ieee.org](mailto:j.c.boemer@ieee.org)

# BACKUP SLIDES

# Approximately 300 Interested Parties

- Most of the inverter-based resource vendors
- Many Transmission Planners
- Many Service Providers & Consultants
- Several Regulatory Bodies
- Supported by Academics & Researchers




Total Results: 65

# WG membership criteria

## ■ PnP's: Clause 4.0 Working Group Membership

- Working Group membership is by individual
- Membership was granted automatically to those attending the kick-off meeting
- Membership shall be **granted after attending two consecutive WG meetings or WG calls**, at request
  - Attendance credit is granted to those who attend  $\geq 50\%$  of a meeting's duration.
  - Attendance via teleconferencing shall count towards the attendance requirements
- Voting member status is maintained through consistent participation at meetings and through Working Group votes
  - may be revoked if a Working Group member misses two consecutive meetings
  - A member who lost voting privileges shall have them reinstated by attendance at two consecutive meetings of the Working Group and upon request for member status
  - Working Group Chair can decide in cases of personal hardship
- Roster / public list includes name, email address, affiliation, and membership status




\* Log WG Mtg attendance via iMAT ([imat.ieee.org](http://imat.ieee.org))

\*\* Available at <https://ieeesa.meetcentral.com/p2800-wspi-p>

# Clarifications of the Scope

- Voluntary standard, requires reference by responsible parties', e.g., interconnection requirements / agreements
  - Candidate parties are transmission owners, state regulators, NERC, and FERC
- Technical minimum requirements, intention is that responsible parties can specify additional requirements
  - Some participants see a risk that it may be regarded as exhaustive requirements
  - Strive for balance between the common denominator and exhaustive requirements
  - May want to consider tiered requirements by use of "performance categories"
- Only "inverter-based" resources, e.g., wind power, solar photovoltaic, energy storage
  - Some participants suggested renaming to "inverter-coupled"
  - "Type 3" wind turbines (doubly-fed induction generators) are in scope
- Applicable to transmission and meshed sub-transmission grids (broad BPS definition)
  - May need different set of requirements for transmission and sub-transmission

# Coordination Approach





# PES Committees to Coordinate with

PES Committee or Subcommittee	Reason	Degree
Electric Machinery Committee	EMC seems to be grabbing scope for inverters used to interface generation to the grid. And Type 3 wind is definitely in their scope	M
Energy Development and Power Generation Committee	I believe they are the sponsor of this WG, so not really a liaison, but mentioned for completeness	n/a
Energy Storage and Stationary Battery Committee	Transmission connected energy storage – it already exists, and more is coming	L
Power System Communications and Cybersecurity Committee	Interoperability with transmission system, external SCADA, and cybersecurity	M
Power System Instrumentation and Measurements Committee	Accuracy requirements for measurements	L
Power System Operation, Planning and Economics Committee	Power systems operations inputs needed for reactive requirements, reactive requirements, etc.; anything involved with running the BPS/BES	M
Power Systems Relaying and Control Committee	Relay and protection requirements and limitations	H
Substations Committee	Requirements related to HVDC and FACTS	L
Surge Protective Devices Committee	Grounding requirements, surge protection	M
Switchgear Committee	Operating voltage requirements, load-rejection overvoltage across breakers	M
Transmission and Distribution (HVDC and FACTS SC)	Requirements applicable to VSC-HVDC included in scope.	H
Transmission and Distribution (Power Quality)	Power quality (harmonics, flicker, etc.) requirements	H
Wind and Solar Power Coordinating Committee	Coordination, communication with stakeholders	M

# IEEE P2800 Leadership Team

Role	Name	Affiliation	Stakeholder Group	Liaison
Chair	Jens C. Boemer	EPRI	Academic/Research	EDP&G, SCC21
Secretary	Wesley Baker	Power Grid Eng.	Service Provider/ Consulting	EMC, IRPTF
Vice-Chair	Bob Cummings	NERC	Regulatory and Governmental Bodies	NERC IRPTF
Vice-Chair	Kevin Collins	FirstSolar	Users, Industrial	NERC IRPTF
Vice-Chair	Babak Enayati	NationalGrid	Stakeholders represented in IEEE Power & Energy Society	T&D, SCC21, PES GovBrd
Vice-Chair	Ross Guttromson	SANDIA National Lab	Academic/Research	DOE
Vice-Chair	Chenhui Niu	State Grid Corporation of China	Stakeholders represented in IEEE P2800.1 Working Group	IEEE P2800.1, IEC SC8A
Vice-Chair	Manish Patel	Southern Company	Utility, Transmission	PSRC, IRPTF
Treasurer	Diwakar Tewari	Leidos	Service Provider/ Consulting	EDP&G

## IEEE P2800 Working Group

### Mailing List

[stds-p2800@listserv.ieee.org](mailto:stds-p2800@listserv.ieee.org)

### Collaborative Workspace for WG Members (only)

<https://ieee-sa.imeetcentral.com/p2800-wspi-p/>

IEEE P2800 SubGroup	Lead (=Officer)	Mailing List
I. Overall Document	Jens C Boemer	<a href="mailto:stds-p2800-sg1@listserv.ieee.org">stds-p2800-sg1@listserv.ieee.org</a>
II. General Requirements	Bob Cummings	<a href="mailto:stds-p2800-sg2@listserv.ieee.org">stds-p2800-sg2@listserv.ieee.org</a>
III. Active Power – Frequency Control	Kevin Collins	<a href="mailto:stds-p2800-sg3@listserv.ieee.org">stds-p2800-sg3@listserv.ieee.org</a>
IV. Reactive Power – Voltage Control	Wes Baker	<a href="mailto:stds-p2800-sg4@listserv.ieee.org">stds-p2800-sg4@listserv.ieee.org</a>
V. Low Short-Circuit Power	Ross Guttromson	<a href="mailto:stds-p2800-sg5@listserv.ieee.org">stds-p2800-sg5@listserv.ieee.org</a>
VI. Power Quality	Ross Guttromson	<a href="mailto:stds-p2800-sg6@listserv.ieee.org">stds-p2800-sg6@listserv.ieee.org</a>
VII. Ride-Through <i>Capability</i> Requirements	Bob Cummings	<a href="mailto:stds-p2800-sg7@listserv.ieee.org">stds-p2800-sg7@listserv.ieee.org</a>
VIII. Ride-Through <i>Performance</i> Requirements	Manish Patel	<a href="mailto:stds-p2800-sg8@listserv.ieee.org">stds-p2800-sg8@listserv.ieee.org</a>
IX. IBR Protection	Babak Enayati	<a href="mailto:stds-p2800-sg9@listserv.ieee.org">stds-p2800-sg9@listserv.ieee.org</a>
X. Modeling & Validation, Measurement Data, and Performance Monitoring	Manish Patel	<a href="mailto:stds-p2800-sg10@listserv.ieee.org">stds-p2800-sg10@listserv.ieee.org</a>
XI. Tests and verification requirements	Chenhui Niu	<a href="mailto:stds-p2800-sg11@listserv.ieee.org">stds-p2800-sg11@listserv.ieee.org</a>

➤ Mailing lists are open to all Interested Parties (“Participants”), not only to WG Members.

# Logistics of Bi-weekly SubGroup

## *P2800 Mailing List at [stds-p2800@listserv.ieee.org](mailto:stds-p2800@listserv.ieee.org)*

P2800 SubGroup	Lead	Mailing List	iMeetCentral Folder	Mon	Tues	Wed	Thurs	Fri
I. Overall Document	Jens Boemer	<a href="mailto:stds-p2800-sg1@listserv.ieee.org">stds-p2800-sg1@listserv.ieee.org</a>	<a href="https://ieee-sa.imeetcentral.com/p/ZgAAAAAAtIIa">https://ieee-sa.imeetcentral.com/p/ZgAAAAAAtIIa</a>				12 PM ET (even weeks)	
II. General Requirements	Bob Cummings	<a href="mailto:stds-p2800-sg2@listserv.ieee.org">stds-p2800-sg2@listserv.ieee.org</a>	<a href="https://ieee-sa.imeetcentral.com/p/ZgAAAAAAtIIb">https://ieee-sa.imeetcentral.com/p/ZgAAAAAAtIIb</a>					3 PM ET (odd weeks)
III. Active Power – Frequency Control	Kevin Collins	<a href="mailto:stds-p2800-sg3@listserv.ieee.org">stds-p2800-sg3@listserv.ieee.org</a>	<a href="https://ieee-sa.imeetcentral.com/p/ZgAAAAAAtIIc">https://ieee-sa.imeetcentral.com/p/ZgAAAAAAtIIc</a>				12 PM ET (odd weeks)	
IV. Reactive Power – Voltage Control	Wes Baker	<a href="mailto:stds-p2800-sg4@listserv.ieee.org">stds-p2800-sg4@listserv.ieee.org</a>	<a href="https://ieee-sa.imeetcentral.com/p/ZgAAAAAAtIIId">https://ieee-sa.imeetcentral.com/p/ZgAAAAAAtIIId</a>		1 PM ET (odd weeks)			
V. Low Short-Circuit Power	Ross Guttromson	<a href="mailto:stds-p2800-sg5@listserv.ieee.org">stds-p2800-sg5@listserv.ieee.org</a>	<a href="https://ieee-sa.imeetcentral.com/p/ZgAAAAAAtIIe">https://ieee-sa.imeetcentral.com/p/ZgAAAAAAtIIe</a>		11 AM ET (odd weeks)			
VI. Power Quality	Ross Guttromson	<a href="mailto:stds-p2800-sg6@listserv.ieee.org">stds-p2800-sg6@listserv.ieee.org</a>	<a href="https://ieee-sa.imeetcentral.com/p/ZgAAAAAAtIIIf">https://ieee-sa.imeetcentral.com/p/ZgAAAAAAtIIIf</a>		11 AM ET (even weeks)			



# Logistics of Bi-weekly SubGroup

## *P2800 Mailing List at [stds-p2800@listserv.ieee.org](mailto:stds-p2800@listserv.ieee.org)*

P2800 SubGroup	Lead	Mailing List	iMeetCentral Folder	Mon	Tues	Wed	Thurs	Fri
VII. Ride-Through Capability Requirements	Bob Cummings	<a href="mailto:stds-p2800-sg7@listserv.ieee.org">stds-p2800-sg7@listserv.ieee.org</a>	<a href="https://ieee-sa.imeetcentral.com/p/ZgAAAAAAtIIg">https://ieee-sa.imeetcentral.com/p/ZgAAAAAAtIIg</a>					3 PM ET (even weeks)
VIII. Ride-Through Performance Requirements	Manish Patel	<a href="mailto:stds-p2800-sg8@listserv.ieee.org">stds-p2800-sg8@listserv.ieee.org</a>	<a href="https://ieee-sa.imeetcentral.com/p/ZgAAAAAAtIIh">https://ieee-sa.imeetcentral.com/p/ZgAAAAAAtIIh</a>			1 PM ET (even weeks)		
IX. IBR Protection	Babak Enayati	<a href="mailto:stds-p2800-sg9@listserv.ieee.org">stds-p2800-sg9@listserv.ieee.org</a>	<a href="https://ieee-sa.imeetcentral.com/p/ZgAAAAAAtIIi">https://ieee-sa.imeetcentral.com/p/ZgAAAAAAtIIi</a>				4 PM ET (odd weeks)	
X. Modeling & Validation, Measurement Data, and Performance Monitoring	Manish Patel	<a href="mailto:stds-p2800-sg10@listserv.ieee.org">stds-p2800-sg10@listserv.ieee.org</a>	<a href="https://ieee-sa.imeetcentral.com/p/ZgAAAAAAtIIj">https://ieee-sa.imeetcentral.com/p/ZgAAAAAAtIIj</a>			1 PM ET (odd weeks)		
XI. Tests and verification requirements	Chenhui Niu	<a href="mailto:stds-p2800-sg11@listserv.ieee.org">stds-p2800-sg11@listserv.ieee.org</a>	<a href="https://ieee-sa.imeetcentral.com/p/ZgAAAAAAtIIk">https://ieee-sa.imeetcentral.com/p/ZgAAAAAAtIIk</a>	Intentionally Delayed				

# Overview of the Project Authorization Request

# IEEE Project Authorization Requests

Project	Scope	Status	Lead	Joint Sponsors / Liaisons	Next Steps
<b>P2800</b> - Standard for Interconnection and Interoperability of Inverter-Based Resources Interconnecting with Associated Transmission Electric Power Systems  <a href="#">Link on myProject</a>	<b>Standard</b> on Performance  <b>(Individual Project)</b>	Approved by NESCOM/SAS B on 9/27/18.	Chair: Dr. Jens Boemer +1.206.471.1180 <a href="mailto:j.c.boemer@ieee.org">j.c.boemer@ieee.org</a>	EDP&G – Sponsor EMC – Joint Sponsor PSRC – Joint Sponsor PSDP – Liaison T&D – Liaison Others, see the figure below	Convene WG at 2019 IEEE PES JTCM in January 2019  <b>Initial Sponsor Ballot: June 2021</b>  Submission to RevCom: October 2022
<b>P2800.1</b> - Guide for Test and Verification Procedures for Inverter-Based Resources Interconnecting with Associated Transmission Electric Power Systems  <a href="#">Link on myProject</a>	<b>Guide</b> on Testing  <b>(Entity Project)</b>	Approved by NESCOM/SAS B on 9/27/18.	c/o China State Grid Dr. Chenhui Niu International Department NARI Group Cooperation +86 13451870987 <a href="mailto:niuchenhui@sgcpri.sgcc.com.cn">niuchenhui@sgcpri.sgcc.com.cn</a>	Same as for P2800, except that PSRC is a Liaison and not a Joint Sponsor	Convene WG at 2019 IEEE PES JTCM in January 2019  Initial Sponsor Ballot: <b>December 2021</b>  Submission to RevCom: October 2022

# IEEE P2800: Standard for Interconnection and Interoperability of Inverter-Based Resources Interconnecting with Associated Transmission Electric Power Systems

## Need for the Project:

The global increase in penetration levels of inverter-based resources is expected to significantly change the dynamic performance of the power grid. As the penetration levels of inverter-based resources increase and the technology of inverter-based resources evolves, specifications and standards are needed to address the performance requirements of inverter-based resources. Currently, there is no one single document of consensus performance requirements covering inverter-based resources interconnected with transmission and sub-transmission systems. Recent events in North America such as the Blue Cut Fire Disturbance as well as institutional challenges in North America that suggest the inappropriate use of IEEE Std 1547 for large-scale solar plants underscore this need. The proposed new standard fulfills this need and can help equipment manufacturers, project developers, transmission planners, and power grid operators improve the quality of the inverter and facility performance to enhance the stability of the power grid. This effort should be aimed to minimize the affected customers and to shorten the time of resynchronizing to the grid if the plant is separated from the grid. Given that IEEE standards are voluntary industry standards, enforcement of any of the requirements specified in this standard will require its adoption by the regional Authority Governing Interconnection Requirements (AGIR); an AGIR is a cognizant and responsible entity that defines, codifies, communicates, administers, and enforces the policies and procedures for allowing electrical interconnection of inverter-based resources interconnecting with associated transmission electric power systems.



# **IEEE P2800: Standard for Interconnection and Interoperability of Inverter-Based Resources Interconnecting with Associated Transmission Electric Power Systems**

## **Scope:**


This standard establishes the recommended **interconnection capability and performance criteria** for inverter-based resources interconnected with transmission and networked sub-transmission systems. Included in this standard are recommendations on performance for reliable integration of inverter-based resources into the bulk power system, including, but not limited to, **voltage and frequency ride-through**, active power control, reactive power control, dynamic active power support under abnormal frequency conditions, **dynamic voltage support under abnormal voltage conditions**, power quality, **negative sequence current injection**, and system protection.

## **Related activities:**

IEC initiative to develop a single framework for connecting and controlling renewables.  
Contact: Charlie Smith, [Charlie@esig.energy](mailto:Charlie@esig.energy) , U.S. TA for SC 8A.

# Disturbance Ride-Through Terminology


# Disturbance performance terminology – IEEE 1547-2018



“Levels” of DER response showing hierarchy of terms/requirements :

- **Ride-through** – ability to withstand voltage or frequency disturbances
  - **Permissive operation** – DER may either continue operation or may cease to energize, at its discretion
    - **Mandatory operation** – required active and reactive current delivery
    - **Momentary cessation** – cessation of energization for the duration of a disturbance with rapid recovery when voltage or frequency return to defined range
  - **Restore output** – DER recovery to normal output following a disturbance that does not cause a **trip**.
- **Trip** – cessation of output without immediate return to service; not necessarily disconnection
  - **Return to service** – re-entry of DER to service following a trip; equivalent to start-up of DER


# Disturbance performance terminology – NERC IRPTF (RL)



“Levels” of DER response showing hierarchy of terms/requirements :

- **Ride-through** – ability to withstand voltage or frequency disturbances
  - **Permissive operation** – DER may either continue operation or may cease to energize, at its discretion
    - **Mandatory operation** – required active and reactive current delivery
    - **Momentary cessation** – cessation of energization for the duration of a disturbance with rapid recovery when voltage or frequency return to defined range
  - **Restore output** – DER recovery to normal output following a disturbance that does not cause a *trip*.
- **Trip** – cessation of output without immediate return to service; not necessarily disconnection
  - **Return to service** – re-entry of DER to service following a trip; equivalent to start-up of DER

# Disturbance performance terminology – NERC IRPTF (RL)



“Levels” of DER response showing hierarchy of terms/requirements :

- **Ride-through** – ability to withstand voltage or frequency disturbances
  - **Permissive operation** – DER may either continue operation or may cease to energize, at its discretion
    - **Mandatory operation** – required active and reactive current delivery
    - **Momentary cessation** – cessation of energization for the duration of a disturbance with rapid recovery when voltage or frequency return to defined range
  - **Restore output** – DER recovery to normal output following a disturbance that does not cause a **trip**.
- **Trip** – cessation of output without immediate return to service; not necessarily disconnection
  - **Return to service** – re-entry of DER to service following a trip; equivalent to start-up of DER