

C37.100.2 Common Requirements for Testing of AC Capacitance Current Switching Devices over 1000V

Chair: Kirk Smith
Secretary: Peter Glaesman

The meeting convened at 1:30 PM on April 3, 2024, with self-introductions of all in attendance. The attendance sheet was passed around and initialed.

Total of 45 attendees. 17 members and 18 guests.

Quorum: Initial indication was that we did not have a quorum, but further review of attendance sheet indicated that a quorum was present. 17 of 29 (?) voting members present.

Patent Slides and Copyright Slides were addressed.

Approve Fall Meeting Minutes – will post on iMeet Central - still need approval.

Approve March Virtual Meeting Minutes - will post on iMeet Central - still need approval.

Today's Topics:

- PAR schedule – Kirk submitted a 1-year extension – through December 2025. To be approved by NESCOM(?).

Kc Values – planning to divide into two tables – showed drafts (NA and NB) for simultaneous and non-simultaneous. After discussion, it was decided that the tables are too difficult to understand. A suggestion is to make additional columns to address all the variables.

Lucas said most cases below 72.5 kV may or may not be effectively grounded, where above 72.5 kV is normally effectively grounded.

- Neil suggests also separating “cables” from “banks”.

Cables – Belted vs Screened for 3-phase, 3-conductor power cables.

<https://blog.usesi.com/2018/09/13/types-of-underground-cables/>

Belted Cables – Belted cables: The three conductors are individually wrapped with insulation and then all three conductors are wrapped with a belt of insulation. A single metallic outer layer covers all three conductors. For capacitive switching, belted cables have capacitance from phase-to-phase and phase-to-ground, similar to overhead lines. Belted cables and overhead lines can be simulated with the parallel combination of as follows:

- a three-phase bank with an ungrounded neutral and
- a three-phase with a grounded neutral.

Screened Cables – Screened cables: The three conductors are individually wrapped with insulation and then individually surrounded by a metallic outer layer. Then, a single metallic outer layer covers all three conductors. For capacitive switching, screened cables have only phase-to-ground capacitance. A screened cable can be simulated with a three-phase with a grounded neutral.

Comments on Tables NA and NB presented at the meeting.

- Jeffrey Brogdon suggests that some of the “notes” in the non-simultaneous table do not apply.
- Neil questioned breaking in a single or two phase-to-phase faults condition.
- Jan explained the situation with European systems and Neil voiced concern over the detail that is glossed over in these summary tables.
 - o Non-effectively grounded includes high impedance grounded and Peterson coil grounding.
- Jeff Brogdon suggests moving cap bank switching down to 2.1 line from 1.5 line. Also, removing Notes 2 & 3 from Table NB.
- Add a NOTE saying that for double circuit towers, 0.1 should be added to Kc.

Another suggestion for the Tables.

- NA
 - o Simultaneous breaking
 - o Ground
 - o Voltage
 - o Delete Note 3
- NB
 - o Banks
- NC
 - o Non-Simultaneous breaking

Jeff reviewed submittal for “Open Wire Line Dropping”.

- Jeff’s presentation will be included in the iMeet Central repository.
- Three cases included - see Slide 15 – Conclusions
 - o CASE 1 – kc=1.2 in C37.100.2-2018 covers all lines considered with interruption of remaining phases at the next available current zero
 - o CASE 2 – kc=1.4 (below 72.5kV) and kc=1.2 (72.5kV and above) with delayed interruption of remaining phases covers:
 - 100% of 46kV lines
 - 80% of 115kV lines
 - 96% of 230kV lines
 - 100% of 500kV lines
 - o CASE 3 – kc=1.4 in C37.012-2022 for breaking line charging current with delayed clearing of the second and third poles covers all lines.
- Why has kc=1.2 worked all these years
 - o Lines not covered are more likely to be loaded. Trapped charge is discharged through the transformer reducing the TRV.
 - o The Breaker design voltage is higher than the operating voltage.
 - o The Polarity sequence of trapped charge reduces TRV half of the time for delayed interruption of remaining phases.

Jeff will Draft an Annex C for explaining derivation of recovery voltage factors.

Kirk displayed Annex K from IEC -100 document applies to circuit breakers. Plan to attempt getting approval to add as an annex to this standard.

Neil explained why controlled switching is not applicable in this standard.

- Some suggested that controlled switching devices should be tested only with the control.
- Others suggested that controlled switching devices should be tested only without the control.

So, at present, the working group is not planning to include controlled switching devices in this revision of the standard.

Pete Kowalik proposed Interrupter Aid Tests material for Section 4.9.

- Neil thinks that this does not belong in this standard, but others disagree.
- Options
 - o Include Interrupter Aid Tests material for Section 4.9 of C37.100.2
 - o OR
 - o Include Interrupter Aid Tests material for Section 6 of C37.30 IEEE Standard Requirements for High-Voltage Switches
- Also refer to IEEE 1247 - IEEE Standard for Interrupter Switches for Alternating Current, Rated Above 1000 Volts. The latest version was published in 2005.
 - o NOTE of the Chair; I think that IEEE 1247 was not revised, and that parts are to be included in other standards.
- The title for Table 5 should Include "for 38 kV and below.
- Whips and Arcing Horns are not included.

Plan for additional and interim meetings was announced and then meeting was dismissed.

- Webex Meeting in Early June 2024
 - Suggest Wednesday June 5, 2024, starting at 12 pm noon East Coast Time.
 - I plan to send out a first draft of the revision before that date.

C37.100.2 Roster and Attendance - April 3, 2024 (session I of I)			
Full Name	Affiliation	Member Status	Present
Brian Roberts	Southern States	member	Y
Bruce Rockwell		member	N
Chris Borck	Eaton	member	N
Chris Morton	Powertech Labs Inc.	member	N
Chuck Corley	Eaton	member	N
Damian Perrin	Entergy Services LLC	member	N
Dan Schiffbauer	Toshiba International Corporation	member	N
Don Steigerwalt	Duke Energy	member	N
Donald Swing	Powell Industries	member	N
Dragan Tabakovic	Hubbell	member	N
Ganesh Balasubramanian	Eaton	guest	Y
Harry Hirz	VESCO	member	Y
Jan Weisker	Siemens Energy	member	Y
Jeff Brogdon	Georgia Transmission	member	Y
Jim Van De Ligt	CANA High Voltage Ltd.	member	N
John Tarleton	Southern States	guest	Y
John Webb	ABB	member	Y
Lucas Collette	Duquene Light	member	Y
Marcus Young	Mitsubishi Electric	member	Y
Michael Christian	ABB	member	Y
Neil McCord	KEC Precision LLC	member	Y
Pete Kowalik	Cleveland/Price Inc.	member	Y
Peter Glaesman	PCORE Electric co.	secretary	Y
Rob Ross	Cleveland/Price	member	Y
Robert Kirkland Smith	Retired	chair	Y
Samuel Zarharko	MEPPI	member	N
Sergio Flores	Schneider Electric Inc, USA	member	Y
Ted Burse	Powell Industries	member	N
Vincent Marshall	Southern Company	member	Y
Roy Alexander	Retired	member	N
Jennifer Santulli	IEEE - SA	staff	N

C37.100.2 Roster and Attendance - April 3, 2024 (session I of I)			
Full Name	Affiliation	Member Status	Present
Carl Kurinko	Hitachi Energy	guest	N
Andrew Chovanec	Power Grid Components	guest	Y
Andy Beckel	Xcel Energy	guest	N
Aryan Bronsveld	Hitachi Energy Sweden	guest	Y
Arben Bufi	MAS Inc.	guest	N
Brad Leccia	Eaton	guest	Y
Brian Berner	Power Grid Components	guest	Y
Bhruken Amin	S&C Electric	guest	Y
Casey Weeks	Siemens Energy	guest	N
Changhoon Lee	Hyosung	guest	Y
Chris Ekpoudom	Southern States	guest	N
Chunming Ma	Burns and McDonnell	guest	N
Conrad Pecile	Meyers Power Products	guest	N
Craig Polchinski	MEPPI	guest	Y
Daniel Gordish	Cleveland/Price	guest	Y
Dan Wolfe	MEPPI	guest	N
Gary Meekings	Southern States	guest	Y
Ilya Glinsky	S&C Electric	guest	Y
Jaden Martz	S&C Electric	guest	Y
Jason Cunningham	Southern States	guest	Y
Jeff Jordan	Southern States	guest	N
Jeremy Moore	Pascor Atlantic	guest	Y
Jerry Wen	BC Hydro	guest	Y
Jon Rogers	Siemens Energy	guest	Y
Jonathan Benge	OG&E	guest	Y
June Seo	HD Hyundai Electric	guest	N
Kaylor Garcia	Utility Solutions, Inc.	guest	N
Lin Tong	TK Switchgear	guest	N
Lissy Diaz	Florida Power & Light	guest	Y
Mark Peterson	Xcel Energy	guest	N
Michelle Antantis	Duquesne Light	guest	Y
Mollie Morehead	Pascor Atlantic	guest	Y
Pedro Castillo	ABB	guest	N

C37.100.2 Roster and Attendance - April 3, 2024 (session I of I)			
Full Name	Affiliation	Member Status	Present
Randy Ward	Aluma-Form	guest	Y
Samuel Anris	KEMA Labs	guest	N
Shahryar Farhang	Megger	guest	Y
Tim Anderson	Aluma-Form	guest	Y
Timothy Terry	Meiden	guest	Y
V. Touns	Siemens Energy	guest	Y
Victor Savulyak	KEMA Labs	guest	Y
Yun Seong Kim	KERI	guest	Y
Yong Woo Lee	KERI	guest	Y
Zachary Beecher	Southern States	guest	Y