

Minutes of Meeting

Working Group C37.010 – Application Guide for AC High-Voltage Circuit Breakers > 1000 VAC Rated on a Symmetrical Basis

Location: Westin Beach (Fort Lauderdale, FL)
Date: Tuesday April 2, 2024 (4:15PM - 6:00PM PST)
Quorum: Membership Count: **40** Members Present: **31**

Agenda

Andy Keels w/ kEElectric Engineering, LLC called the meeting to order and presented the agenda.

Introduction of Members and Guests

Introductions and attendance gathered in -person
68 Total in Attendance (31 Members, 37 Guests) – Quorum Achieved

Review of Attendance Logging via IEEE Attendance Tool

See meeting slides for details

Review of IEEE Patent and Copyright Policies

No Essential Patent Claims noted

Review of Schedule and Future Meetings

Quorum Check: 31 Members – Quorum Achieved

Review of Reference Documents loaded into IMeetCentral

Motion: Approve October 9, 2023 In-Person Meeting Minutes: Carl Schuetz

2nd to the Motion: David Mitchell

Vote: Approved without objection/abstention

Motion: Approve January 17, 2024 Virtual Meeting Minutes: Carl Schuetz

2nd to the Motion: David Mitchell

Vote: Approved without objection/abstention

Review of References to existing Standards

All standards are in “Reference Documents” section of IMeet Central

Table 6 & Table 7 Presentation/Discussion

- See minutes slides
- Comments related to recommendation to add a cautionary note to Table 6:
 - o What additional design components may need to be considered when exceeding temperature limits. For example, glue joints may fail suddenly vs. components that will fail due to aging.
 - o Should the aging behavior of epoxy and composite materials (not part of the current path) be considered.

- Comments related to the significance of overload capability/duration general guidance within the current guide that the utility uses to calculate overload condition.
 - o Additional cautionary comments and notes being considered for inclusion in the document should either be removed or clarified. They reduce effectiveness of existing equations within the guide.
- Comment noted existing thermal time constants are based on oil circuit breakers. This is addressed in Section 4.5.4.2 of the existing document.
- Actions:
 - o Task force consisting of Dan Schiffbauer, Carl Schuetz and Dan Benedict will review cautionary notes in more detail and provide recommendation to the working group at a future meeting.
 - o Chair will delete the second sentence of proposed additional cautionary note and add to the draft document. Next review of the draft document during virtual meeting in August 2024 will follow-up on this topic.

Sub-Group presentation of Update on User-Specified 105% of Rated Maximum Voltage.

- See slides in Meeting Minutes
- General Comment:
 - o Most utilities do not exceed 100% of the rated maximum voltage because that would be a NERC violation.
- Comments to Clause 4.2 Revision Recommendation:
 - o In addition to short circuit functions, it is recommended to add the following: capacitive, inductive, load switching, and other applicable switching duties.
 - o Reference should be made to the maximum operating voltage in C37.04 vs C84.1.
 - o Add a reference back to C37.06 bibliography for referring back to circuit breakers qualified prior to 2018.
- Member presented a proposed paragraph that suggests the use of TRV multiplying factors to cover circuit breaker operation over the maximum rated value
 - o Actions:
 - Victor Hermisillo to post the proposal in IMeetCentral for the working group to review.

Sub-Group presentation of Update on Inverter Based Resources and the Impact on Fault Currents

- See slides in Meeting Minutes
- General Comments/Questions:
 - o What is the fault output capability of the IBR based on the algorithms internal to the equipment.
 - o Utility representative commented that their company has lots of data that could be used to support the sub-groups evaluation (fault current and voltage oscillographs).

Presentation of Topic related to HV CB Generator Synchronization Scope Proposal

- See Slides in Meeting Minutes
- The following members formed a sub-group to evaluate this proposal:
 - o Jan Weisker, Dave Mitchell, Andy Chovanic, Victor Hermisillo
- Action:
 - o Chair to add proposal discussion to next meeting agenda

Schedule

Next Virtual Meeting: August 23, 2023 @ 11:00AM EST

Next in-person meeting: October 13th – 17th, 2024 at the Oklahoma City, OK

Meeting adjourned by the chair at 6:00PM (EST) on 4/2/2024

Reported by:

Jeremy Hensberger, Lucas Collette & Andy Keels

| | Name | Affiliation | Member |
|----|----------------------------|--|---------------|
| 1 | Aristizabal, Mauricio | Hitachi Energy USA | |
| 2 | BECKEL, ANDREW | Xcel Energy | |
| 3 | Becker, George | POWER Engineers, Inc. | X |
| 4 | Beecher, Zachary | Southern States LLC | |
| 5 | Benedict, Dan | PPL Corporation | X |
| 6 | Benge, Jonathan | Oklahoma Gas and Electric | |
| 7 | Bolar, Sanket | Oncor Electric | |
| 8 | Bornuat, Albane | General Electric Company (GE); GRID SOLUTIONS | |
| 9 | Brogdon, Jeffrey | Georgia Transmission Corporation | |
| 10 | Bryant, Craig | Duke Energy | X |
| 11 | Bufl, Arben | Meiden America Switchgear | X |
| 12 | byreddy, sudarshan reddy | Burns & McDonnell | |
| 13 | Chovanec, Andrew | Power Grid Components | X |
| 14 | Collette, Lucas | Duquesne Light Co. | X |
| 15 | Crawford, Michael | Mitsubishi Electric Power Products, Inc. (MEPPI) | X |
| 16 | Cunningham, Jason | Southern States LLC | |
| 17 | Cuppett, Matthew | Hitachi Energy | |
| 18 | Eastman, Maxwell | Black and Veatch | |
| 19 | Flores, Sergio | Schneider Electric USA Inc. | |
| 20 | Hanna, Robert | JST Power Equipment Inc | X |
| 21 | Hensberger, Jeremy | Mitsubishi Electric Power Products Inc | X |
| 22 | Hermosillo, Victor | GE Grid Solutions | X |
| 23 | Irwin, Todd | GE Grid Solutions | X |
| 24 | Jaggernauth, Sudesh | Florida Power & Light | |
| 25 | Jarnigan, Christopher | southern company/ southern nuclear | X |
| 26 | Keels, Thomas | kEElectric Engineering, PLLC | X |
| 27 | Krause, Dwight | Black and Veatch | |
| 28 | Kurinko, Carl | Hitachi Energy | X |
| 29 | Lee, Yongwoo | Korea Electrotechnology Research Institute(KERI) | |
| 30 | Livshitz, Albert | Schneider Electric | X |
| 31 | Lopez, Leo | WIKA | |
| 32 | Ma, Chunming | Burns & McDonnell | |
| 33 | Marshall, Vincent | southern company/ southern nuclear | X |
| 34 | MARZEC, PETER | S and C Electric Co | |
| 35 | May, Steven | Southern Company Services | X |
| 36 | McGlown, Kevin | JST Power Equipment | |
| 37 | Meekins, Gary | Southern States LLC | |
| 38 | Mitchell, David | Southern States LLC | X |
| 39 | Natale, Anthony | HICO America | |
| 40 | Ordein, Fernando | Dominion Energy | X |
| 41 | Orosz, Miklos | CBT&S Consulting LLC | |
| 42 | Pecile, Conrad | Myers Power Products, Inc, | |
| 43 | Pedreras Ratmiroff, Javier | GE Grid Solutions | |
| 44 | Peterson, Mark | Xcel Energy | |
| 45 | Polchinski, Craig | Mitsubishi Electric Corporation | X |
| 46 | Pounders, Isaac | Meiden America Switchgear | |

| | | | |
|----|---------------------|---|-----------|
| 47 | Rebovich, Justin | GE Vernova; General Electric Company (GE) | |
| 48 | Rexroad, Aaron | Meiden America Switchgear inc. | X |
| 49 | Ricciuti, Anthony | Eaton Corporation | X |
| 50 | Roberts, Brian | Southern States LLC | |
| 51 | Sax, Benjamin | Nashville Electric Service | |
| 52 | Schiffbauer, Daniel | Toshiba International Corporation | X |
| 53 | Schuetz, Carl | American Transmission Co., LLC | X |
| 54 | Scott, Jeffrey | Ameren | X |
| 55 | Sharma, Devki | Entergy Corporation | X |
| 56 | Shirode, Aniket | ABB Ltd. | |
| 57 | Skidmore, Michael | American Electric Power (AEP) | |
| 58 | Tarleton, John | Southern States LLC | |
| 59 | Terry, Timothy | meiden | |
| 60 | Toups, Vernon | Siemens Energy Inc | X |
| 61 | Usner, Joseph | AEP | |
| 62 | Webb, John | ABB Ltd. | |
| 63 | Weeks, Casey | Siemens Energy, Inc. | X |
| 64 | Weisker, Jan | Siemens Energy | X |
| 65 | Woodyard, Terry | Siemens Industry, Inc. | |
| 66 | York, Richard | Mitsubishi Electric Corporation | |
| 67 | Young, Marcus | Mitsubishi Electric Power Products, Inc. | X |
| 68 | Zaharko, Samuel | Mitsubishi Electric Corporation | X |
| | | Members Present | 31 |
| | | Guests Present | 37 |

C37.010 Working Group

Application Guide for AC High-Voltage Circuit Breakers >1000Vac
Rated on a Symmetrical Basis

Tuesday, April 2nd, 2024

16:15 – 18:00 EDT

Chair: T. Andy Keels w/ kEElectric Engineering, PLLC

Secretary: Jeremy Hensberger w/ MEPPi

Vice-Chair: Lucas Collette w/ Duquesne Light Co.

Starting Document: IEEE Std C37.010-2016 (Revision of C37.010-1999)


Agenda

1. Chairman's call to order
2. Introduction of attendees:
Please announce your *Name, Affiliation, Location*
3. Attendance Logging Instructions
4. Workgroup Required Reading
5. Anticipated Schedule (*Best laid plans*)
6. iMeet Central Workspace
7. Minutes Approval
8. Discussion of Table 6 and Table 7 (Dan Benedict w/ PPL Energy)
9. Report from Sub-group on "User-Specified 110% Voltage Duty" (Carl Schuetz w/ ATC)
10. Proposed revision on TRV multiplying factors (Victor Hermosillo w/ GE HVCB)
11. Call for additional revisions to Section 4 or Section 5, or Annex A or B
12. Next meetings

Logging Your ATTENDANCE To This Meeting

There are three way to get there:

1. Go To: IEEE SA eTools, Then click on **IEEE Attendance Tool**
2. **Google**: IEEE Attendance Tool
3. Go directly to: <https://imat.ieee.org/my-site/home>



The screenshot shows a web browser window displaying the IEEE Attendance Tool sign-in page. The URL in the address bar is <https://imat.ieee.org/my-site/home>. The page features the IEEE logo and a "Sign In" section. Below the logo, it says "Welcome to the IEEE Attendance Tool" and "Please use your IEEE Account username and password to begin using this system". A note states: "An IEEE Account provides IEEE members, IEEE-SA Members and other valued users access to a variety of IEEE online services." The sign-in form includes fields for "Username/Email:" and "Password:", a "Sign in to:" dropdown menu set to "Attendance Tool", and a checkbox for "By accessing the myProject application you agree that you have read and accept the IEEE Privacy Policy." A "Sign In" button is located below the form. At the bottom of the page, there is a link for "Need an IEEE Account or forgot your username or password?" and a copyright notice: "Copyright © 2021 IEEE Standards Association. All rights reserved. Software by bivio."

Type in the Email address &
Password that you use for your
IEEE activities

Don't forget to check the box
acknowledging the IEEE Privacy
Policy

Logging Your ATTENDANCE To This Meeting

[Attendance](#) | [Reports](#) | [Events](#) | [Setup](#) | [Export](#)




Home - Thomas Keels, SA PIN: 88780

Welcome to the IEEE Attendance Tracking system. This system provides on-site home tracking integrated with the IEEE myProject™ system. You can view your prior attendance on the [Attendance History Report](#).

Active Meetings

Please select the meeting you are currently attending

| | | |
|---|----------------|-------------|
|  IEEE PES Switchgear Spring 2024 Meeting | Ft. Lauderdale | 02-Apr-2024 |
| IEEE P802.3dj COM Implementation and Execution Ad Hoc meeting | | 02-Apr-2024 |
| 802 April/May/June Telecons | | 01-Apr-2024 |
| IEEE 802.3 test meeting | | 29-Mar-2024 |
| IEEE 802.18 teleconference call (24/03/24 to 09/05/24) | | 21-Mar-2024 |
| 802.11 Telecons (March 19-May 10) | | 19-Mar-2024 |
| 802.1 Telecons (Mar-May) | | 18-Mar-2024 |

Logging Your ATTENDANCE To This Meeting

Then select the Working Group

If it is a 'virtual meeting' the WG Chair should have the link listed here

[Attendance](#) | [Reports](#) | [Events](#) | [Setup](#) | [Export](#)



[Home](#) >> [Attendance](#)

→ IEEE PES Switchgear Spring 2024 Meeting ([edit](#))

Ft. Lauderdale, FL

IEEE PES Switchgear Spring 2024 Committee Meetings

Westin Beach Resort

Ft. Lauderdale, FL

Select Working Group

→ [PE/SWG/HVCB-WG_C37.010 Attendance](#)

Workgroup Required Reading

IEEE SA STANDARDS ASSOCIATION [Create](#) [Help/Resour](#)

[Dashboard](#) [Workspaces](#) [C37.010 HVCB App...](#) [Home](#) [Wiki](#) [Files & Discussions](#) [Project Management](#) [Calendar](#) [People](#) [Help](#) [Settings](#)

Files by Folder

- All Items
- Attachments
- C37.010 HVCB Applications Workg
 - Attendance Documents (4)
 - Communications
 - Contributions
 - Draft Documents (2)
 - Meeting Agendas (3)
 - Meeting Minutes (1)
 - Approved Minutes (1)
 - Unapproved Minutes (2)
 - Member Roster (1)
 - PAR (1)
 - Reference Documents (16)
 - Required Reading for WG**
 - Standard Development (1)

C37.010 HVCB A... / Required Reading for WG Membership

[Upload](#) [New](#) [Sort by Last](#)

| | | | |
|--------------------------|---|------------|-------------|
| <input type="checkbox"/> | IEEE Patent Slides.pdf | Andy Keels | Apr 24 2022 |
| <input type="checkbox"/> | IEEE SA Copyright Policy 2019.pdf | Andy Keels | Apr 24 2022 |
| <input type="checkbox"/> | IEEE Policies 2022.pdf | Andy Keels | Apr 21 2022 |
| <input type="checkbox"/> | IEEE_Code_of_Conduct.pdf | Andy Keels | Apr 21 2022 |

Showing 1-4 of 4

Meeting Schedule

- ~~04/11/2022 1st working group meeting~~
- ~~10/17/2022 2nd working group meeting Burlington, VT~~
- ~~02/03/2023 3rd working group meeting VIRTUAL Google Meeting~~
- ~~04/26/2023 4th working group meeting Virtual WebEx~~
- ~~07/19/2023 5th working group meeting VIRTUAL WebEx~~
- ~~10/10/2023 6th working group meeting San Diego, CA~~
- 04/02/2024 7th working group meeting Ft. Lauderdale, FL
- 08/23/2024 8th working group meeting VIRTUAL WebEx
- 10/14/2024 9th working group meeting Oklahoma City, OK
- 01/02/2025 10th working group meeting VIRTUAL WebEx
- 04/07/2025 11th working group meeting Orlando, FL

C37.010 Working Group












- Review of WG Membership Master List
 - Quorum Check
- Review of iMeet Central Workspace
- Approval of Minutes of last meeting

Current Member List For Quorum Check

- | | | | |
|----|-----------------------|----|---------------------|
| 1 | Aaron Rexroad | 21 | Jan Weisker |
| 2 | Albert Livishitz | 22 | Jeff Scott |
| 3 | Andrew Chovanec | 23 | Jeff Ward |
| 4 | Anthony Ricciuti | 24 | Jennifer Hunter |
| 5 | Arben Bufi | 25 | Jeremy Hensberger |
| 6 | Carl Kurinko | 26 | Lucas Colette |
| 7 | Carl Schuetz | 27 | Marcus Young |
| 8 | Casey Weeks | 28 | Matt Westerdale |
| 9 | Chris Jarnigan | 29 | Michael Christian |
| 10 | Craig Bryant | 30 | Michael Crawford |
| 11 | Craig Polchinski | 31 | Miklos Palazzo |
| 12 | Dan Benedict | 32 | R. Kirk Smith |
| 13 | Dan Shiffbauer | 33 | Robert Hanna |
| 14 | <i>David Caverly*</i> | 34 | Samuel Zaharko |
| 15 | David Mitchell | 35 | Steven May |
| 16 | Devki Sharma | 36 | Thomas 'Andy' Keels |
| 17 | Don Steigerwalt | 37 | Todd Irwin |
| 18 | Mikos Orosz | 38 | Vernon Toups |
| 19 | George Becker | 39 | Victor Hermosillo |
| 20 | Jake Walgenbach | 40 | Vincent Marshall |
| | | 41 | Wei Zhang |

C37.010 Working Group

Files by Folder ▾

-  All Items
-  Attachments
-  C37.010 HVCB Applications Workg
 -  Attendance Documents (4)
 -  Communications
 -  Contributions
 -  Draft Documents (2)
 -  Meeting Agendas (3)
 -  Meeting Minutes (1)
 -  Approved Minutes (1)
 -  Unapproved Minutes (2)

C37.010 HVCB A... / Meeting Minutes / Unapproved Minutes ▾

Options ▾

Upload ▾ New ▾

Sort by Last Modified ▲



| | | | | |
|--------------------------|---|-------------|--------------------|--------------------------|
| <input type="checkbox"/> |  Minutes C37.010 2022-10-17 Rev.1.pdf Andy Keels | Nov 02 2022 | ⬅ Pending Approval | <input type="checkbox"/> |
| <input type="checkbox"/> |  S22 C37.010 Minutes Rev0.docx Andy Keels | Nov 02 2022 | ⬅ Draft | <input type="checkbox"/> |

Showing 1-2 of 2

C37.010 Working Group

Reference Standards for IEEE PES C37.010 Working Group

| Got It | Std Number | Year | Title |
|--------|---------------------|------|--|
| | C37.010-2016 & 1999 | | Application Guide for AC High-Voltage Circuit Breakers > 1000 Vac Rated on a Symmetrical Current Basis |
| | C37.04-2018 | | Standard Rating Structure for AC High-Voltage Circuit Breakers Rated on a Symmetrical Current Basis |
| | C37.04a-2003 | | Standard Rating Structure for AC High-Voltage Circuit Breakers Rated on a Symmetrical Current Basis: Amendment 1 Capacitance Current Switching |
| | C37.06-2009 & 2018 | | Standard for AC High-Voltage Circuit Breakers Rated on a Symmetrical Current Basis—Preferred Ratings and Related Required Capabilities for Voltages Above 1000 V |
| | C37.09-2018 | | Standard Test Procedure for AC High-Voltage Circuit Breakers Rated on a Symmetrical Current Basis |
| | C37.09a-2005 | | Standard Test Procedure for AC High-Voltage Circuit Breakers Rated on a Symmetrical Current Basis- Amendment 1: Capacitance Current Switching |
| | C37.09b-2010 | | Standard Test Procedure for AC High-Voltage Circuit Breakers Rated on a Symmetrical Current Basis -- Amendment 2 |
| | C37.011-2019 | | Guide for the Application of Transient Recovery Voltage for AC High-Voltage Circuit Breakers with Rated Maximum Voltage above 1000 V |
| | C37.012-2014 | | Guide for the Application of Capacitance Current Switching for AC High-Voltage Circuit Breakers Above 1000 V |
| | C37.017-2020 | | Standard for Bushings for High-Voltage [over 1000 V (ac)] Circuit Breakers and Gas-Insulated Switchgear |
| | C37.015-2017 | | Guide for the Application of Shunt Reactor Switching |
| | C37.20.2-2015 | | Standard for Metal-Clad Switchgear |
| | C37.24-2017 | | Guide for Evaluating the Effect of Solar Radiation on Outdoor Metal-Enclosed Switchgear |
| | C37.81-2017 | | Guide for Seismic Qualification of Class 1E Metal-Enclosed Power Switchgear Assemblies |
| | C37.100-1992 ?? | | Standard Definitions for Power Switchgear |
| | C37.100.1-2018 ? | | Standard for Common Requirements for High-Voltage Power Switchgear Rated Above 1000 V |
| | C57.106-2015 | | Guide for Acceptance and Maintenance of Insulating Mineral Oil in Electrical Equipment |
| | ANSI C37.7-1960 ?? | | INTERRUPTING RATING FACTORS FOR RECLOSING SERVICE FOR AC HIGH-VOLTAGE CIRCUIT BREAKERS RATED ON A TOTAL CURRENT BASIS |
| | IEC 62271-100-2021 | | High-voltage switchgear and controlgear - Part 100: Alternating-current circuit-breakers |

C37.010 Working Group

IEEE SA STANDARDS ASSOCIATION

Create ▾
Help/R

Dashboard Workspaces ▾

C37.010 HVCB App...
Home
Wiki
Files & Discussions
Project Management ▾
Calendar
People
Help
S

Files by Folder ▾

- All Items
- Attachments
- C37.010 HVCB Applications Workg
 - Attendance Documents (4)
 - Communications
 - Contributions
 - Draft Documents (2)
 - Meeting Agendas (3)
 - Meeting Minutes (1)
 - Approved Minutes (1)
 - Unapproved Minutes (2)
 - Member Roster (1)
 - PAR (1)
 - Reference Documents (16)
 - Required Reading for WG Me
 - Standard Development (1)
- Trash

C37.010 HVCB A... / Reference Documents ▾

Upload ▾
New ▾

Sort I

| | | | | |
|--------------------------|--------------------------|---|-------------------|-------------|
| <input type="checkbox"/> | <input type="checkbox"/> | C37.75 D2.1 Pre-publication 2022Nov14.pdf | Andy Keels | Nov 15 2022 |
| <input type="checkbox"/> | <input type="checkbox"/> | C57.106-2015.pdf | Jennifer Santulli | Oct 28 2022 |
| <input type="checkbox"/> | <input type="checkbox"/> | C37.81-2017.pdf | Jennifer Santulli | Oct 28 2022 |
| <input type="checkbox"/> | <input type="checkbox"/> | C37.24-2017 (1).pdf | Jennifer Santulli | Oct 28 2022 |
| <input type="checkbox"/> | <input type="checkbox"/> | C37.20.2-2015.pdf | Jennifer Santulli | Oct 28 2022 |
| <input type="checkbox"/> | <input type="checkbox"/> | C37.100.1-2018.pdf | Jennifer Santulli | Oct 28 2022 |
| <input type="checkbox"/> | <input type="checkbox"/> | C37.100-1992.pdf | Jennifer Santulli | Oct 28 2022 |
| <input type="checkbox"/> | <input type="checkbox"/> | C37.017-2020.pdf | Jennifer Santulli | Oct 28 2022 |
| <input type="checkbox"/> | <input type="checkbox"/> | C37.012-2014.pdf | Jennifer Santulli | Oct 28 2022 |
| <input type="checkbox"/> | <input type="checkbox"/> | C37.09-2018 (1).pdf | Jennifer Santulli | Oct 26 2022 |
| <input type="checkbox"/> | <input type="checkbox"/> | C37.04a-2003.pdf | Jennifer Santulli | Oct 26 2022 |
| <input type="checkbox"/> | <input type="checkbox"/> | C37.04-2018 (1).pdf | Jennifer Santulli | Oct 26 2022 |
| <input type="checkbox"/> | <input type="checkbox"/> | C37.015-2017.pdf | Jennifer Santulli | Oct 26 2022 |
| <input type="checkbox"/> | <input type="checkbox"/> | C37.09b-2010.pdf | Jennifer Santulli | Oct 26 2022 |
| <input type="checkbox"/> | <input type="checkbox"/> | C37.09a-2005.pdf | Jennifer Santulli | Oct 26 2022 |

Discussion of Table 6 & Table 7

C37.010 working group meeting
April 2, 2024

Dan Benedict
Andy Chovanec
Dan Schiffbauer

Goal of sub-workgroup
Clarify Table 6 and Table 7 related to emergency load
current-carrying capability

Discussion of Table 6 and Table 7

Proposed Changes

- Added Section 3 – definitions, acronyms, and abbreviations; updated subclause references throughout
- Updated values within Tables 3-11 to correct minor errors and round consistently
- Added θ_{max} of 95 °C column to relevant tables
- Caution statement if exceeding rated temperature limits of circuit breaker:

Extreme care must be exercised by the equipment operator when exceeding the total temperature limits for the circuit breaker. There could be auxiliary components not identified in IEEE Std. C37.04 or IEEE Std. C57.13 that suddenly fail at temperatures greater than the standard total temperature limits. The manufacturer should be consulted prior to the total temperature limits being exceeded to determine if any components would not tolerate a higher temperature.

Discussion of Table 6 and Table 7

Proposed Changes (cont'd)

- Separated continuous current equation based on ambient temperature

$$I_a = I_r \left[\frac{\theta_{\max} - \theta_a}{\Delta\theta_r} \right]^{\frac{1}{1.8}} \quad \longrightarrow \quad I_a = \begin{cases} I_r \left[\frac{\theta'_{\max} - \theta_a}{\Delta\theta'_r} \right]^{\frac{1}{1.8}} & \text{for } \theta_a \leq 40 \text{ }^\circ\text{C} \\ I_r \left[\frac{\theta''_{\max} - \theta_a}{\Delta\theta''_r} \right]^{\frac{1}{1.8}} & \text{for } \theta_a > 40 \text{ }^\circ\text{C} \end{cases}$$


- Clarified 4 h and 8 h emergency load current-carrying capabilities

$$I_e = \begin{cases} I_r \left[\frac{\theta'_{\max} + 15 \text{ }^\circ\text{C} - \theta_a}{\Delta\theta'_r} \right]^{\frac{1}{1.8}} = I_r \left[\frac{\theta'_{\max} - 25 \text{ }^\circ\text{C}}{\Delta\theta'_r} \right]^{\frac{1}{1.8}} & \text{for a 4-h emergency period} \\ I_r \left[\frac{\theta'_{\max} + 10 \text{ }^\circ\text{C} - \theta_a}{\Delta\theta'_r} \right]^{\frac{1}{1.8}} = I_r \left[\frac{\theta'_{\max} - 30 \text{ }^\circ\text{C}}{\Delta\theta'_r} \right]^{\frac{1}{1.8}} & \text{for an 8-h emergency period} \end{cases}$$

Discussion of Table 6 and Table 7

Proposed Changes (cont'd)

- Updates to Tables 6 and 7 → creation of new Tables



Discussion of Table 6 and Table 7

Proposed Changes (cont'd)

- Update to Table 4

Table 4—Typical thermal time constants

| Circuit breaker category | Typical thermal time constant τ (h) |
|--|---|
| Circuit breakers in metal-metal -clad switchgear | 0.5 <u>IEEE Std. C37.20.2</u> |
| Circuit breaker in gas-insulated switchgear <u>(GIS)MEGIS</u> | 0.5 |
| Circuit breakers not in metal- enclosed <u>clad</u> switchgear and not <u>in GISMEGIS</u> | 0.5 |

- Added Annex C for derivations and example calculations

Sub-Group Update

HVCB Operation at 105% of Rated Maximum Voltage

C37.010 meeting
Ft. Lauderdale-April 2023

Arben Bufi
Andrew Chovanec
Luke Collette
Craig Polchinski
Carl Schuetz
Markus Young

Goal of the Sub-Group

To provide more detailed guidance in the application guide for users when the power system is operated up to 5% above nameplate voltage value

(10% above system nominal voltage as defined in C84.1)

- No proposition is made to change the rating structure or its values

Update on clause 4.2 revision

4.2 Maximum voltage for application

The operating voltage should not exceed the rated maximum voltage of the circuit breaker. The rated maximum voltage is the voltage on which all the corresponding type tests have been based. The type tests values include some margins in order to accommodate aging as well as statistical behavior.

- Two online meetings were held to discuss the revisions and draft recommended content
- The recommended content is thought to provide greater clarity for the understanding of what aspects rated maximum voltage (RMV) have on circuit breaker performance
- Guidance is also provided to have the user perform some means of determining what the recovery voltages are (for varying conditions) and discuss these (and other voltage capability aspects) with the manufacturer

ANSI C84.1 - Table 1: Standard nominal voltages and voltage

| VOLTAGE CLASS | Nominal System Voltage | | | Nominal Utilization Voltage (Note h) | Voltage Range A (Note b) | | | Voltage Range B (Note b) | | |
|----------------------|-----------------------------|---|---------------------|--------------------------------------|--|---------------------|--|---|---|---------------------|
| | (Note a) | | | | Maximum | Minimum | | Maximum | Minimum | |
| | 2-wire | 3-wire | 4-wire | | Utilization and Service Voltage (Note c) | Service Voltage | Utilization Voltage | Utilization and Service Voltage | Service Voltage | Utilization Voltage |
| Low Voltage (Note 1) | <i>Single-Phase Systems</i> | | | | | | | | | |
| | 120 | 120/240 | | 115 | 126 | 114 | 110 | 127 | 110 | 106 |
| | | | | 115/230 | 126/252 | 114/228 | 110/220 | 127/254 | 110/220 | 106/212 |
| | <i>Three-Phase Systems</i> | | | | | | | | | |
| | | 208Y/120 (Note d) 240/120 | 200 | 218Y/126 | 197Y/114 | 191Y/110 | 220Y/127 | 191Y/110 (Note 2) 220/110 | 184Y/106 (Note 2) 212/106 | |
| | 240 | 480Y/277 | 230/115 | 252/126 | 228/114 | 220/110 | 254/127 | 220/110 | 212/106 | |
| | 480 | | 460Y/266 | 504Y/291 | 456Y/263 | 440Y/254 | 508Y/293 | 440Y/254 | 424Y/245 | |
| | 600 (Note e) | | 460 | 504 | 456 | 440 | 508 | 440 | 424 | |
| | | | 575 | 630 (Note e) | 570 | 550 | 635 (Note e) | 550 | 530 | |
| Medium Voltage | 2400 | | | 2520 | 2340 | 2160 | 2540 | 2280 | 2080 | |
| | 4160 | 4160Y/2400 | | 4370/2520 | 4050Y/2340 | 3740Y/2160 | 4400Y/2540 | 3950Y/2280 | 3600Y/2080 | |
| | 4800 | | | 4370 | 4050 | 3740 | 4400 | 3950 | 3600 | |
| | 6900 | | | 5040 | 4680 | 4320 | 5080 | 4560 | 4160 | |
| | | | | 7240 | 6730 | 6210 | 7260 | 6560 | 5940 | |
| | | 8320Y/4800 | | 8730Y/5040 | 8110Y/4680 | (Note f) | 8800Y/5080 | 7900Y/4560 | (Note f) | |
| | | 12000Y/6930 | | 12600Y/7270 | 11700Y/6760 | | 12700Y/7330 | 11400Y/6580 | | |
| | | 12470Y/7200 | | 13090Y/7560 | 12160Y/7020 | | 13200Y/7620 | 11850Y/6840 | | |
| | | 13200Y/7620 | | 13860Y/8000 | 12870Y/7430 | | 13970Y/8070 | 12504Y/7240 | | |
| | 13800 | 13800Y/7970 | | 14490Y/8370 | 13460Y/7770 | 12420 | 14520Y/8380 | 13110Y/7570 | 11880 | |
| | 20780Y/12000 | | 21820Y/12600 | 20260Y/11700 | | 22000Y/12700 | 19740Y/11400 | | | |
| | 22860Y/13200 | | 24000Y/13860 | 22290Y/12870 | (Note f) | 24200Y/13970 | 21720Y/12540 | (Note f) | | |
| | 23000 | 24940Y/14400 | 24150 | 24320Y/14040 | | 24340 | 21850 | | | |
| | 34500 | 34500Y/19920 | 26190Y/15120 | 33640Y/19420 | | 26400Y/15240 | 23690Y/13680 | | | |
| | | | 36230Y/20920 | 33640 | | 36510Y/21080 | 32780Y/18930 | | | |
| | 46000 | | 36230 | | | 36510 | 32780 | | | |
| | 69000 | | 72000 | Maximum Voltage (Note g) 48300 | NOTE 1—Minimum utilization voltages for 120-600 volt circuits not supplying lighting loads are as follows: | | NOTE 2—Many 220-volt motors were applied on the assumption that the utilization voltage would be less than 187 volts. Caution should be exercised in applying the Range B minimum voltages of table 1 and note (1) to existing 208-volt systems supplying such motors. | | | |
| High Voltage | 115000 | | | 121000 | Nominal System Voltage | Range A | Range B | | | |
| | 138000 | | | 145000 | 120 | 108 | 104 | | | |
| | 161000 | | | 169000 | 120/240 | 108/216 | 104/208 | | | |
| | 230000 | | | 242000 | * 208Y/120 | 187Y/108 | 180Y/104 | | | |
| Extra-High Voltage | 345000 | | | 362000 | 240/120 | 216/108 | 208/104 | | | |
| | 400000 | | | 420000 | 240 | 216 | 208 | | | |
| | 500000 | | | 550000 | 480Y/277 | 432Y/249 | 416Y/240 | | | |
| | 765000 | | | 800000 | 480 | 432 | 416 | | | |
| Ultra-High Voltage | 1100000 | | | 1200000 | 600 | 540 | 520 | | | |

IEEE Standards References on RMV Ratings

IEEE C37.04-2018

5.2 Rated maximum voltage (V) or (U_r)

The rated maximum voltage of a circuit breaker is the highest rms phase-to-phase voltage for which the circuit breaker is designed, and is the upper limit for operation. Rated maximum voltage has the same meaning as maximum system voltage rating referred to in ANSI C84.1 [B3].

IEEE C37.010-2016

4.2 Maximum voltage for application

The operating voltage should not exceed the rated maximum voltage of the circuit breaker. The rated maximum voltage is the voltage on which all the corresponding type tests have been based. The type tests values include some margins in order to accommodate aging as well as statistical behavior.

ANSI C84.1-2006

- (g) For these systems, Range A and Range B limits are not shown because, where they are used as service voltages, the operating voltage level on the user's system is normally adjusted by means of voltage regulators or load tap-changers to suit their requirements.

IEEE Standards References on RMV Ratings

IEEE C37.09-2018

4.2 Maximum voltage tests

There is no specific test to demonstrate this rating. However, the ability of the circuit breaker to operate successfully at rated maximum voltage is demonstrated by performing short-circuit current interruption and other current switching rating tests in accordance with Table 1, and specified values of circuit transient recovery voltage (TRV), as given in IEEE C37.04.

IEEE Standards References on RMV Ratings

IEEE C37.09-2018

Table 1—Single-phase or three-phase test duties for short-circuit current tests

| Test duty | Operating duty | Test voltage (kV) | Making I [kA (pk)] | Short-circuit current (kA) | % asymmetry @ contact part |
|--------------------------------------|---|------------------------|----------------------|----------------------------|----------------------------|
| T10 | O-t _r -CO-t' _r -CO | E | | $0.1 I$ | <20 |
| T30 | O-t _r -CO-t' _r -CO | E | | $0.3 I$ | <20 |
| T60 | O-t _r -CO-t' _r -CO | E | | $0.6 I$ | <20 |
| T100s | O-t _r -CO-t' _r -CO or T100s(a) and T100s(b) | E | $F \times I$ | I | <20 |
| T100s(a) | C-t' _r -C | E | $F \times I$ | | |
| T100s(b) | O-t _r -O-t' _r -O | E | | I | <20 |
| T100a | Three Os | E | | see 4.8.4.4 | >20 |
| Single-phase fault tests | | | | | |
| T100s 1ph | O | | | | <20 |
| T100a 1ph | O | $\frac{U_r}{\sqrt{3}}$ | | see 4.8.4.5 | >20 |
| Single-phase, short-line fault tests | | | | | |
| L75 | Three Os | $\frac{U_r}{\sqrt{3}}$ | | $0.7 I$ to $0.8 I$ | <20 |
| L90 | Three Os | $\frac{U_r}{\sqrt{3}}$ | | $0.9 I$ to $0.95 I$ | <20 |
| Short-time current test | | | | | |
| STC | Closed position | | $F \times I$ | I for T seconds | |

Testing voltage 'E'

$$E = \frac{k_{pp}}{\sqrt{3}} \times U_r$$

U_r is Rated maximum voltage

k_{pp} is First-pole-to-clear factor:

1.3 for grounded neutral systems

1.5 for isolated neutral systems.

Rated TRV ' u_c '

$u_c = 1.49 \times U_r$, for $k_{pp} = 1.3$

$u_c = 1.72 \times U_r$, for $k_{pp} = 1.5$

Clause 4.2 Revision Recommendation

The operating voltage should not exceed the rated maximum voltage of the circuit breaker. The rated maximum voltage is the voltage on which all the corresponding type tests have been based, including the short circuit interrupting capability tests. Some values used in the short circuit interrupting type tests include margins in order to accommodate aging and statistical behavior.

Informative NOTE:

If system voltage operation above values ascribed in ANSI C84.1 voltage Range A are experienced, the system TRV and switching recovery voltages must remain within the circuit breaker capability as demonstrated in the type test reports. These system recovery voltage values should be confirmed on a case-by-case basis performed by system study, calculation, or some other means. For such cases, it is recommended that the user consults the manufacturer to verify the dielectric withstand and recovery voltages capabilities of selected circuit breaker.

Impact of inverters on fault current calculation methods

- Luke Collette
- Craig Polchinski
- Carl Schuetz
- Marcus Young

Learnings to date

- The IEEE Power Systems Relay Committee (PSRC) has authored a technical report that describes how available fault current calculation software programs determine phasor domain fault current from an Inverter Based resource (IBR)
 - PES-TR78 “ Modification of Commercial Fault Calculation Programs for Wind Turbine Generators”
- The IBR fault current consists of transient and controlled response periods
 - Since the software solutions are prepared in the phasor domain a different approach is needed to determine peak currents in the first cycle (see Fig. 4-8 in PES-TR78)
 - Presently this different approach is to perform simulations in a time domain transient analysis program
- The dynamic period fault currents are determined by the control algorithm and its settings

Learnings to date (cont'd.)

- A liaison representative from PSRC was provided to help guide the sub-group request for information regarding transient currents from an IBR
- An online meeting was held to determine:
 - A) if the PSRC has intentions to investigate transient IBR currents
 - B) determine any additional fault current calculation learnings since the TR
 - C) if the fault current calculation software companies have plans to model transient currents
- The answer to these inquiries are:
 - A) the PSRC presently has no intention of determining transient currents
 - B) the transient period current for an IBR is best based on transient time domain simulations
 - The accuracy of those simulations within the transient period is not known since the simulation performer does not typically have the manufacturers component data and algorithm
 - C) the software companies have not expressed an interest in determining transient currents
 - EPRI has a project to do so

Learnings to date (cont'd.)

- PES TR-78 provide examples of relay oscillography that recorded the phase current for different faults
 - The oscillography shows asymmetric current present for 2 – 3 cycles, supplied by Type III Wind Turbine Generators (Figs. 4-8, 4-15, 4-17)
 - Only Type III WTG fault currents were provided
- A research paper within IEEE Xplore titled “Study On The Fault Current Transient Features of the PV Inverter” provides transient simulation currents for three-phase faults
 - Transient currents are present for $\sim \frac{1}{2}$ cycle however, they do not exhibit a high degree of asymmetry
 - The transient period duration and current magnitude are significantly reduced when an enhanced control algorithm is used in the converter controller

Initial conclusions and recommendation for further work

- The fault current calculation software companies can model IBR fault currents in the phasor domain but not in the time domain
- Peak transient currents may be dependent on what type of IBR generation is present
 - Type III WTG / Type IV WTG, PV-VSC converter, BES-VSC converter
- Time domain simulation methods may not adequately capture the transient period fault currents since the actual component values and control algorithms are not known

RECOMMENDATION

Develop a user Request for Oscillography data of IBR fault currents and send to users

Proposed paragraph that suggests the use of TRV multiplying factors to cover circuit breaker operation over the maximum rated voltage


It is possible to apply a circuit breaker tested for ungrounded conditions at its maximum rated voltage in applications operating over this voltage with a reduction of TRV factors and limiting its use to solidly grounded networks. For terminal fault short-circuit current breaking, it is necessary that the circuit tested be tested with a combination of peak TRV with first pole to clear factor (k_{pp}) of 1.5 and demonstration of an arcing window width for k_{pp} of 1.3. For out-of-phase breaking, if testing was performed with 2.5 factor, it can cover applications at higher operating voltage with a reduced 2.0 factor. In the case of capacitive load current switching, a circuit breaker tested to 1.4 voltage factor (k_v) can be applied at higher operating voltage with a reduced k_v of 1.2 that still covers lines, cables and grounded shunt capacitor banks.

Contributed by: Victor Hermossillo, GE Vernova HVCB, 3/28/2024

Open Call for Additional Suggestions for Revisions

Contents

| | |
|---|-----|
| 1. Overview..... | 14 |
| 1.1 Scope..... | 14 |
| 1.2 Purpose..... | 14 |
| 2. Normative references..... | 14 |
| 3. General service conditions..... | 15 |
| 3.1 Usual service conditions..... | 15 |
| 3.2 Unusual service conditions..... | 16 |
| 3.3 Mechanical considerations for outdoor circuit breakers..... | 20 |
| 4. Application considerations..... | 20 |
| 4.1 General..... | 20 |
| 4.2 Maximum voltage for application..... | 21 |
| 4.3 Voltage range factor..... | 21 |
| 4.4 Frequency..... | 21 |
| 4.5 Continuous current..... | 21 |
| 4.6 Rated dielectric withstand..... | 34 |
| 4.7 Standard operating duty..... | 35 |
| 4.8 Interrupting time..... | 35 |
| 4.9 Permissible tripping delay T (determined by short-time current test duration)..... | 37 |
| 4.10 Reclosing time..... | 38 |
| 4.11 Short-circuit current rating..... | 42 |
| 4.12 Transient recovery voltage (TRV)..... | 54 |
| 4.13 Load current switching capability and life (repetitive operation)..... | 54 |
| 4.14 Capacitance current switching..... | 54 |
| 4.15 Line closing (line-closing switching surge factor for circuit breakers 362 kV and above)..... | 55 |
| 4.16 Switching lines with series capacitors..... | 61 |
| 4.17 Conditions of use with respect to the out-of-phase switching current rating..... | 61 |
| 4.18 Shunt reactor current switching..... | 62 |
| 4.19 Transformer current switching..... | 63 |
| 4.20 Controlled switching..... | 63 |
| 4.21 Transformer limited fault (TLF) duties..... | 65 |
| 4.22 Mechanical endurance..... | 65 |
| 4.23 Rated control voltage..... | 66 |
| 4.24 Fluid operating pressure..... | 66 |
| 4.25 Insulating oil for circuit breaker..... | 66 |
| 4.26 Closed pressure system (gas-filled)..... | 66 |
| 4.27 Circuit breakers limiting factors for associated equipment..... | 66 |
| 4.28 Circuit breakers equipped with resistors..... | 67 |
| 4.29 Service capability..... | 70 |
| 5. Short-circuit considerations..... | 70 |
| 5.1 System short-circuit currents..... | 70 |
| 5.2 Methods for calculating system short-circuit currents..... | 73 |
| 5.3 Electrical quantities used..... | 85 |
| 5.4 Selection of applicable circuit breaker ratings..... | 90 |
| Annex A (informative) Basis for E/X method corrected for ac and dc decrements in the calculation of short-circuit currents..... | 92 |
| Annex B (informative) Circuit breakers directly connected to motors..... | 112 |



webex
by **CISCO**

**Next On-Line Meeting will be
via IEEE WebEx**

**Friday, August 23 2024
13:00pm EDT (10am PDT)**



Our Next in-person meeting is scheduled to be at:

Omni Hotel, Oklahoma City, OK

October 13 - 17, 2024

**Would someone like to
make a motion to
adjourn?**

