C37.21 Working Group met on Monday, April 29 with 4 members and 4 guests.

Administrative Items:

- 1. C37.21 has approval to ballot.
- 2. Quebec City Fall 2001 action item was to submit Draft 8 for Sub-Committee review. This was not done.
- 3. Newport, RI Action Item Submit C37.21 draft 9 Sub-Committee for review. Anticipate comments on wiring across hinges.
- 4. Newport, RI Action Item Request editorial review by IEEE.
- 5. Balloting process will not be initiated until after Draft 9 comments are received back.

Substantive Issues Discussed:

6. Wiring types

Previous drafts had harmonized with C37.20.1 and C37.20.2. WG recognizes that Switchboards may include devices varying from Electronic Relays with communications to devices with RTD wiring to Computers with ribbon cables to devices accepting with fiber optics.