

Report to IEEE SWC, S/C: ADSCOM

WG PC37.301, Milwaukee, Wisconsin, 4 October 2006

1. Meeting

Meeting was from 15h45 to 17h20; 7 members and 10 guests participate.

Patent slides have been shown. No patent issues have been raised.

The WG reviewed possible changes that comes from the bibliographic review. Regarding field tests this item will not be consider for inclusion in the actual revision. The IEC document 60060-3 on dielectric field tests do not include partial discharge.

Ed Jankowitch, who reviewed the definitions, recommends to adopt definitions of IEC60270.

The chairman produced and circulated a comparison table of actual 1291, IEC 60270 and IEEE PC57.113 (transformer committee). The WG feel that it may be preferable to adopt part or all of IEC 60270. Marcel Fortin, Bob Behl and Frank Decesaro will analyse the documents and prepare recommendation for the end of 2006, to be letter ballot to the WG before spring 2007 meeting.

2. WG or TF decision

- To adopt definitions of IEC 60270; appropriate copyrights shall than be obtained.
- To adopt part or all of IEC 60270; appropriate copyrights shall than be obtained.

3. Course of action

- Marcel Fortin, Bob Behl and Frank Decesaro: analyse IEC 60270 and recommend parts that could be adopted. Deadline: December 2006.
- Marcel Fortin: letter ballot among the WG the recommendation regarding adoption of part or all of IEC 60270. Deadline: April 2006.
- Marcel Fortin: prepare D2, with definitions from IEC 60270.
- Marcel Fortin: initiate appropriate procedure to obtain copyrights from IEC.

Marcel Fortin, ing
12 October 2006

1293 Lussier, Ste-Julie, QC J3E 1Y2

téléphone: 450 922 0925; cell : 514 258 8604; courriel: fortin.marcel@ieee.org