

Request Study Group for C37.20.7 IEEE Guide for Testing Switchgear Rated Up to 52 kV for Internal Arcing Faults

- To add an additional accessibility type suffix in Annex C to evaluate the performance characteristics of switchgear with the breaker door open.
- Other topics deemed by study group
- Submit PAR if required